

Used Generator Information

Asset Data Information

Stock Number	XP22503
Set Manufacturer	Aksa
Set Model	ACQ 2250

Set Serial No:	33178713
Year Of Manufacture	2010
Price	£145,000.00

Alternator Data

kVA	2250 Standby
kW	1800
Volts	400/230
Hz	50
Amps	3251
Make	Stamford
Model	PI 734 F1
Serial No:	0260918/001
RCD	Yes
MCB ACB	4 Pole ACB
PMG AREP	PMG
Heater	No

Engine Data

Make	Cummins
Model	QSK60-G4
Serial No:	33178713
Hours	181
Exhaust	External
Bellows	Yes
Voltage	24
Batteries / Battery Type	Lead Acid
Battery Isolator	No
Water Jacket Heater	Yes
Lube oil top up	No
Racor Filter	No
3 Way Fuel Valve	No

Fuel Tank Data

Skid / Free Standing	No
Single Skin / Bunded	No
Capacity Litres	No
Capacity Hours @ 75%	No
Fuel Gauge	No
Transfer Pump	No

Enclosure Data

Open / Skid	No
Sound Attenuated	Yes
Containerised	Yes
Sound Level 75% @ 1m	70
Length mm	11440
Width mm	3550
Height mm (excl exhaust)	3720
Height mm (incl exhaust)	4720
Colour	Beige & Grey
Condition	Very good
Lighting AC / DC	Yes
Bunded Floor	Yes

Lifting Data / Chassis

Weight Kg	29,000
Corner / Centre Point	Eyes on chassis
Forklift Pockets	No
Trailer	No

Control Panel Data

Make	DeepSea DSE5220
LED / Analog	LED
Hour Meter	Yes
Oil	Yes
Water	Yes
Battery	Yes
Amp	Yes
Volts	Yes
Hz	Yes
AMF - Parallel	AMF
Battery Charger	Yes

Additional Data

Sockets	No
---------	----

Ex Datacentre standby unit



All Diesel Generators Are Inspected And Tested Prior To Dispatch

• Diesel Generating Sets • Lighting Towers • Spares & Service Parts • Acoustic Enclosures • Fuel Storage Solutions • Electrical Control and Distribution Switchboards •