

Used Generator Information

Asset Data Information	
Stock Number	XP6002
Set Manufacturer	ENER-G
Set Model	
Set Serial Number	1403
Year Of Manufacture	2005
Price	
Date Into Stock	Apr-21

Alternator Data	
kVA	610 Prime
kW	488
Volts	415
Hz	50
Amps	880
Make	Stamford
Model	HC-I544E1
Serial No:	0246613/001
RCD	x
MCB ACB	850 amp / 3-Pole
PMG AREP	✓
Heater	x

Engine Data	
Make	Perkins
Model	4008-30TR51
Serial No:	DEHH01D5U164275
Hours	
Exhaust	✓
Bellows	✓
Voltage	24
Batteries / Battery Type	2 X AGM
Battery Isolator	✓
Water Jacket Heater	✓
Lube oil top up	✓
Racor Filter	x
3 Way Fuel Valve	x

Fuel Tank Data	
Skid / Free Standing	N/A
Single Skin / Bunded	
Capacity Litres	
Capacity Hours @ 75%	
Fuel Gauge	
Transfer Pump	

Enclosure Data	
Open / Skid	✓
Sound Attenuated	✓
Containerised	x
Sound Level 75% @ 7m	
Length mm	4640
Width mm	2860
Height mm (excl exhaust)	2756
Height mm (incl exhaust)	N/A
Colour	Grey
Condition	Good
Lighting AC / DC	✓
Bunded Floor	✓

Lifting Data / Chassis	
Weight Kg	11,000
Corner / Centre Point	x
Forklift Pockets	x
Trailer	x

Control Panel Data	
Make	ENER-G
LED / Analog	✓
Hour Meter	
Oil	
Water	
Battery	
Amp	
Volts	
Hz	
AMF - Parallel	✓
Battery Charger	✓

Additional Data	
Sockets	1 x 13 Amp

In running order (these engines are good for 100,000 plus hours before major overhaul). Ex NHS hospital In silent canopy to about 65 dba at 1 mts. Has sustained some minor damage during removal .



All Diesel Generators Are Inspected And Tested Prior To Dispatch